Nordic TSOs quarterly cross zonal capacity report

Quarter 1, 2020 - TSO version

Background and Purpose

Quarter 1, 2020

This quarterly report on cross-zonal transmission capacity is produced by the Nordic TSOs by the request of NordREG, an organization for the Nordic energy regulators.

The Nordic TSOs determine the capacity on each cross-zonal corridor every hour of the day. The purpose of this report is to provide the reader with information about

• the available cross-zonal capacity on corridors between the Nordic countries and between the Nordics and continental Europe, and

• the reasons why the cross-zonal capacity has been reduced in the cases where capacity has been reduced below a threshold of 70 % of max NTC as an average over the quarter

The report consists of

• an overview over all corridors,

- detailed information on each corridor with hourly values and
- description of reoccurring and/or significant capacity reductions

Table of contents	
Overall summary	2
Summary analysis of all AC and DC corridors	3
Overall quarterly day ahead capacities and flows – percent of max NTC	3
Overall quarterly day ahead capacities and flows - MW	4
Percentage of time where capacity is larger than 70 % of max NTC	5
Individual corridor analysis	6
DK1-DE	6
DK1-NO2	8
DK1-SE3	10
DK2-DE	12
DK2-SE4	14
FI-EE	16
FI-SE1	18
FI-SE3	20
NO1-SE3	22
NO2-NL	24
NO3-SE2	26
NO4-SE1	28
NO4-SE2	30
SE4-DE	32
SE4-LT	34
SE4-PL	36
Appendix	38
Definitions and clarifications	38
Contact information	39

Summary

For all corridors (34 in total) the available capacity provided by the TSOs was 82% of max NTC as a weighted average, compared to the threshold of 70%.

For AC corridors (14 in total) the available capacity provided by the TSOs was 79% of max NTC as a weighted average, compared to the threshold of 70%.

For DC corridors (20 in total) the available capacity provided by the TSOs was 85% of max NTC as a weighted average, compared to the threshold of 70%.

The number of corridors under 70% was 5. The corridor(s) with the lowest average available capacity compared to Max NTC was DE-SE4, with 33%.





Figure 1: Cross-zonal day-ahead capacity result for all corridors, showing average weekly capacity given as a percentage of max NTC. The capacity is summed independent of direction.

Overall quarterly day ahead capacities and flows - percent of max NTC - AC 100 % 50 % Export 0 % Import -50 % -100 % DK1-DE DK2-SE4 FI-SE1 NO1-SE3 NO3-SE2 NO4-SE2 NO4-SE1 Day ahead capacity export Day ahead capacity import Day ahead flow export Day ahead flow import -- 70% of max NTC export -- 70% of max NTC import

Figure 2: Cross-zonal day-ahead capacity result for AC corridors, showing average capacity given and flow as a percentage of max NTC. Available capacity is given for all hours,



but the average flow is only given for hours with flow in that direction. For a corridor A-B, export means flow from A to B and import means flow from B to A.

Figure 3: Cross-zonal day-ahead capacity result for DC corridors, showing average capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. For a corridor A-B, export means flow from A to B and import means flow from B to A.

Overall quarterly day ahead capacities and flows - MW - AC




Figure 4: Cross-zonal day-ahead capacity result for AC corridors, showing average capacity given and flow in MW. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. For a corridor A-B, export means flow from A to B and import means flow from B to A.




Figure 5: Cross-zonal day-ahead capacity result for DC corridors, showing average capacity given and flow in MW. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. For a corridor A-B, export means flow from A to B and import means flow from B to A.



Percentage of time where capacity is larger than 70% of max NTC - AC




Figure 6: Shows the percentage of hours when the day-ahead capacity for AC corridors given to the energy marked is above 70% of the max NTC. For a corridor A-B, export means flow from A to B and import means flow from B to A.




Figure 7: Shows the percentage of hours when the day-ahead capacity for DC corridors given to the energy marked is above 70% of the max NTC. For a corridor A-B, export means flow from A to B and import means flow from B to A.





Figure 8: Shows cross-zonal day-ahead capacity result for the AC corridor DK1-DE, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to DE, while import indicates flow from DK1. DE to DK1.



DK1-DE: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 9: Shows cross-zonal day-ahead capacity result for the AC corridor DK1-DE, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to DE, while import indicates flow from DE to DK1.

DK1-DE: hourly day ahead capacities and flows - MW





Figure 10: Shows cross-zonal day-ahead capacity result for the AC corridor DK1-DE, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to DE, while import indicates flow from DE to DK1.



DK1-DE: price comparison in EUR

Figure 11: Shows day-ahead prices for the AC corridor DK1-DE, all prices are in EUR. The red line shows the price difference between the two areas.







Figure 12: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-NO2, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to NO2, while import indicates flow from NO2 to DK1.



DK1-NO2: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 13: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-NO2, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to NO2, while import indicates flow from NO2 to DK1.

DK1-NO2: hourly day ahead capacities and flows - MW







Figure 14: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-NO2, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to NO2, while import indicates flow from NO2 to DK1.



DK1-NO2: price comparison in EUR

Figure 15: Shows day-ahead prices for the HVDC corridor DK1-NO2, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 16: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-SE3, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to SE3, while import indicates flow from SE3 to DK1.



DK1-SE3: hourly mean day ahead capacities and flows - percent of max NTC

Quarter 1, 2020

Figure 17: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-SE3, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to SE3, while import indicates flow from SE3 to DK1.

DK1-SE3: hourly day ahead capacities and flows - MW





Figure 18: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK1-SE3, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK1 to SE3, while import indicates flow from SE3 to DK1.



DK1-SE3: price comparison in EUR

Figure 19: Shows day-ahead prices for the HVDC corridor DK1-SE3, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 20: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK2-DE, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to DE, while import indicates flow from DK2. DE to DK2.



DK2-DE: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 21: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK2-DE, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to DE, while import indicates flow from DE to DK2.





Figure 22: Shows cross-zonal day-ahead capacity result for the HVDC corridor DK2-DE, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to DE, while import indicates flow from DE to DK2.



DK2-DE: price comparison in EUR

Figure 23: Shows day-ahead prices for the HVDC corridor DK2-DE, all prices are in EUR. The red line shows the price difference between the two areas.

Published: 2020.04.21





Figure 24: Shows cross-zonal day-ahead capacity result for the AC corridor DK2-SE4, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to SE4, while import indicates flow from SE4 to DK2.




DK2-SE4: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 25: Shows cross-zonal day-ahead capacity result for the AC corridor DK2-SE4, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to SE4, while import indicates flow from SE4 to DK2.

DK2-SE4: hourly day ahead capacities and flows - MW 2 000 1 000 Export 0 Import -1 000 -2 000 1 30,12,20,9 05.01.2020 26.01.2020 02.02.2020 09.02.2020 13.02.7020 07.03,2020 0803,7070 29.03, 2020 12.01.2020 19.01.2020 16.02.2020 15.03.2020 12.03.1020 Day ahead capacity export Day ahead capacity import Day ahead flow export Day ahead flow import - Max NTC export Max NTC import Flow - limited import/export

Figure 26: Shows cross-zonal day-ahead capacity result for the AC corridor DK2-SE4, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from DK2 to SE4, while import indicates flow from SE4 to DK2.



DK2-SE4: price comparison in EUR

Figure 27: Shows day-ahead prices for the AC corridor DK2-SE4, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 28: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-EE, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to EE, while import indicates flow from EE to FI.



FI-EE: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 29: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-EE, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to EE, while import indicates flow from EE to FI.





Figure 30: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-EE, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to EE, while import indicates flow from EE to FI.



FI-EE: price comparison in EUR

Figure 31: Shows day-ahead prices for the HVDC corridor FI-EE, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 32: Shows cross-zonal day-ahead capacity result for the AC corridor FI-SE1, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE1, while import indicates flow from SE1 to FI.



FI-SE1: hourly mean day ahead capacities and flows - percent of max NTC

Figure 33: Shows cross-zonal day-ahead capacity result for the AC corridor FI-SE1, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE1, while import indicates flow from SE1 to FI.

FI-SE1: hourly day ahead capacities and flows - MW





Figure 34: Shows cross-zonal day-ahead capacity result for the AC corridor FI-SE1, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE1, while import indicates flow from SE1 to FI.



FI-SE1: price comparison in EUR

Figure 35: Shows day-ahead prices for the AC corridor FI-SE1, all prices are in EUR. The red line shows the price difference between the two areas.




Figure 36: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-SE3, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE3, while import indicates flow from SE3 to FI.




Figure 37: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-SE3, showing average per hour of the day (1-24) capacity given and flow as a percentage of

max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE3, while import indicates flow from SE3 to FI.

FI-SE3: hourly day ahead capacities and flows - MW





Figure 38: Shows cross-zonal day-ahead capacity result for the HVDC corridor FI-SE3, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from FI to SE3, while import indicates flow from SE3 to FI.



FI-SE3: price comparison in EUR

Figure 39: Shows day-ahead prices for the HVDC corridor FI-SE3, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 40: Shows cross-zonal day-ahead capacity result for the AC corridor NO1-SE3, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO1 to SE3, while import indicates flow from SE3 to NO1.



NO1-SE3: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 41: Shows cross-zonal day-ahead capacity result for the AC corridor NO1-SE3, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO1 to SE3, while import indicates flow from SE3 to NO1.




Figure 42: Shows cross-zonal day-ahead capacity result for the AC corridor NO1-SE3, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO1 to SE3, while import indicates flow from SE3 to NO1.




Figure 43: Shows day-ahead prices for the AC corridor NO1-SE3, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 44: Shows cross-zonal day-ahead capacity result for the HVDC corridor NO2-NL, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO2 to NL, while import indicates flow from NL to NO2.



NO2-NL: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 45: Shows cross-zonal day-ahead capacity result for the HVDC corridor NO2-NL, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO2 to NL, while import indicates flow from NL to NO2.

NO2-NL: hourly day ahead capacities and flows - MW




Figure 46: Shows cross-zonal day-ahead capacity result for the HVDC corridor NO2-NL, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO2 to NL, while import indicates flow from NL to NO2.




Figure 47: Shows day-ahead prices for the HVDC corridor NO2-NL, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 48: Shows cross-zonal day-ahead capacity result for the AC corridor NO3-SE2, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO3 to SE2, while import indicates flow from SE2 to NO3.



NO3-SE2: hourly mean day ahead capacities and flows - percent of max NTC

Quarter 1, 2020

Figure 49: Shows cross-zonal day-ahead capacity result for the AC corridor NO3-SE2, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO3 to SE2, while import indicates flow from SE2 to NO3.

NO3-SE2: hourly day ahead capacities and flows - MW




Figure 50: Shows cross-zonal day-ahead capacity result for the AC corridor NO3-SE2, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO3 to SE2, while import indicates flow from SE2 to NO3.




Figure 51: Shows day-ahead prices for the AC corridor NO3-SE2, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 52: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE1, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE1, while import indicates flow from SE1 to NO4.



NO4-SE1: hourly mean day ahead capacities and flows - percent of max NTC

Quarter 1, 2020

Figure 53: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE1, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE1, while import indicates flow from SE1 to NO4.

NO4-SE1: hourly day ahead capacities and flows - MW




Figure 54: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE1, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE1, while import indicates flow from SE1 to NO4.




Figure 55: Shows day-ahead prices for the AC corridor NO4-SE1, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 56: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE2, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE2, while import indicates flow from SE2 to NO4.



NO4-SE2: hourly mean day ahead capacities and flows - percent of max NTC

Quarter 1, 2020

Figure 57: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE2, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE2, while import indicates flow from SE2 to NO4.

NO4-SE2: hourly day ahead capacities and flows - MW




Figure 58: Shows cross-zonal day-ahead capacity result for the AC corridor NO4-SE2, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from NO4 to SE2, while import indicates flow from SE2 to NO4.




Figure 59: Shows day-ahead prices for the AC corridor NO4-SE2, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 60: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-DE, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to DE, while import indicates flow from DE to SE4.



SE4-DE: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 61: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-DE, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to DE, while import indicates flow from DE to SE4.

SE4-DE: hourly day ahead capacities and flows – MW





Figure 62: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-DE, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to DE, while import indicates flow from DE to SE4.



SE4-DE: price comparison in EUR

Figure 63: Shows day-ahead prices for the HVDC corridor SE4-DE, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 64: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-LT, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to LT, while import indicates flow from LT to SE4.



SE4-LT: hourly mean day ahead capacities and flows - percent of max NTC

Figure 65: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-LT, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to LT, while import indicates flow from LT to SE4.





Figure 66: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-LT, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to LT, while import indicates flow from LT to SE4.



SE4-LT: price comparison in EUR

Figure 67: Shows day-ahead prices for the HVDC corridor SE4-LT, all prices are in EUR. The red line shows the price difference between the two areas.





Figure 68: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-PL, showing average weekly capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to PL, while import indicates flow from PL to SE4.



SE4-PL: hourly mean day ahead capacities and flows – percent of max NTC

Quarter 1, 2020

Figure 69: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-PL, showing average per hour of the day (1-24) capacity given and flow as a percentage of max NTC. Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to PL, while import indicates flow from PL to SE4.





Figure 70: Shows cross-zonal day-ahead capacity result for the HVDC corridor SE4-PL, showing capacity given and flow (MW). Available capacity is given for all hours, but the average flow is only given for hours with flow in that direction. Export indicates flow from SE4 to PL, while import indicates flow from PL to SE4.



SE4-PL: price comparison in EUR

Figure 71: Shows day-ahead prices for the HVDC corridor SE4-PL, all prices are in EUR. The red line shows the price difference between the two areas.

DEFINITIONS AND CLARIFICATIONS

The table below defines the terms used in this report and provides clarifying text to assist the reader.

TERM	DEFINTION or CLARIFICATION
Net Transfer Capacity	•The Net Transfer Capacity (NTC, NTC = TTC-TRM) is the maximum exchange program between two areas compatible with security standards applicable in both areas and taking into account the technical uncertainties on future network conditions.
The Total Transfer Capacity	•The Total Transfer Capacity (TTC) is the maximum exchange program between two areas compatible with operational security standards applicable at each system if future network conditions, generation and load patterns were perfectly known in advance.
The Transmission Reliability Margin	 The Transmission Reliability Margin (TRM) is a security margin that copes with uncertainties on the computed TTC values arising from: a) Unintended deviations of physical flow during operation due to the physical functioning of load-frequency regulation b) Emergency exchanges between TSOs to cope with unexpected unbalanced situations in real time c) Inaccuracies, e. g. in data collection and measurements

Published: 2020.04.21

Contact information

This report was prepared on behalf of the Nordic Synchronous Area. For further information, please contact: <u>landssentral@statnett.no</u>, or <u>driftanalys2@svk.se</u>.



Visiting address Nydalen allé 33, 0484 Oslo

Postal address PB 4904 Nydalen, 0423 Oslo

Enterprise No. NO 962 986 633 MVA

Т	+47 23 90 30 00
F.	+47 23 90 30 01

W statnett.noE firmapost@statnett.no



Visiting address Sturegatan 1, Sundbyberg

Postal address Svenska kraftnät, Box 1200, 172 24 Sundbyberg

T 010-475 80 00 (växel)

- F 010-475 89 50
- W svk.se
- E registrator@svk.se

ENERGINET

Visiting address Tonne Kjærsvej 65, 7000 Fredericia, Denmark

Postal address Tonne Kjærsvej 65, 7000 Fredericia, Denmark

- T +45 70 10 22 44 F +45 76 24 51 80
- W energinet.dk
- E info@energinet.dk

FINGRID

Visiting address Läkkisepäntie 21, 00620 Helsinki, Finland

Postal address P.O.Box 530, 00101 Helsinki, Finland

- T +358 30 395 5000
- F +358 30 395 5196
- W fingrid.fi

Description of capacity reductions below 75% of NTC in Q1 2020

Statnett:

NO1-SE3: Reduced due to fault in 420 kV Tegneby substation and cable fault on 420 kV Rød-Hasle.

NO4-SE2: Reduced within the normal operating range.

NO2-DK1: Reduced due to cable fault on SK4.

Fingrid:

FI-EE, Finland-Estonia

The capacity was reduced on the interconnector between FI and EE on W1 due to Estlink 2 failure and planned outages EstLink 1 new automatic functions testing on W10 and W11.

FI-SE1, Finland-Sweden North

The capacity was reduced on the AC interconnectors between FI and SE1 due to planned outages affected to the interconnectors. The outages were Keminmaa-Djuptjärn transmission line outage on W2,

Svartbyn-Djuptjärn transmission line and Petäjäskoski-Letsi transmission line outages on W12.

FI-SE3, Finland-Sweden Middle

The capacity was reduced on the interconnectors between FI and SE3 due to planned outage affected to the interconnectors. The outage was Fenno-Skan 2 HVDC-links outage on W11.

Energinet:

DK1 –DE

Main portion of the limitations has been caused by expansion work in the northern part of the German grid. Project work has been ongoing on the Danish side of the interconnector as well. Again, in Q1 2020 this work has mainly been related to the sectioning of the Danish 400 kV station Kassø in preparation for the strengthened 400 kV interconnector and following increased capacity. It is worth mentioning that the capacity released to the market is still virtual. The physical capacity is far lower than the day ahead capacity and vast amounts of energy is countertraded.

NO2 – DK1

The main reason for limitations on this interconnector in Q1 2020 has been the recent faults on the SK4 cable. These have forced ENDK and SN to change the operational pattern of the connection as a whole (SK1234) in order to facilitate system as well as asset security. The changed operational pattern has resulted in reduced capacity on the connection. The duration of this limitation is unknown. Intense work is ongoing in order to facilitate increased available capacity on the interconnector.

Svenska Kraftnät

The corridors below have been reduced with an average of lower than 70 % of NTC.

SE2-NO4, Sweden-Norway

The reasons for reductions set by Svenska kraftnät were planned outage of the interconnector and planned outage near the interconnector. The major part of the reductions were set by Statnett.

SE3-NO1, Sweden-Norway

The reasons for reductions set by Svenska kraftnät were congestion in the West Coast Corridor, planned outage on the interconnector, planned outage near the interconnector, and unavailable system protection. Additional reductions were set by Statnett.

SE4-DE, Sweden-Germany

The reasons for reductions set by Svenska kraftnät were congestion in the West Coast Corridor and failure near the interconnector. The major part of the reductions were set by TenneT.

SE4-PL, Sweden-Poland

The reason for reductions set by Svenska kraftnät was congestion in the West Coast Corridor.

The major part of the reductions were set by PSE.

Reoccurring capacity reductions in Q4 2019

Svenska Kraftnät

The West Coast corridor is a section in the Swedish national grid, close to Gothenburg in SE3, which might be congested in normal operation. This typically occurs during night and weekends with a large northbound transfer of power over the West Coast Corridor. The congestion leads to reduction of SE3 to NO1, DK1 to SE3, DK2 to SE4, DE to SE4, PL to SE4, and LT to SE4. For more information see: <u>https://www.nordpoolgroup.com/message-center-container/newsroom/tsonews/2016/q4/no.-332016---updated-routine-for-congestion-management-for-thewest-coast-corridor-in-sweden/</u>