

Instructions

Instructions for the Safety Supervisor LV

Document ID: [SDOK-515-56](#), revision: 4.0

Confidentiality: K0 Statnett open information, can be shared with everyone

This copy was downloaded 30.12.2022 by [Jon Halvor Holtet](#).

The original document may have been published in a new revision or revoked since this copy was downloaded.

The current revision of this document can be downloaded here:

<https://samhandling.statnett.no/styrendedok/Dok.aspx?id=SDOK-515-56&language=1033>

Team: [Elsikkerhet](#)

Responsible: [Jon Halvor Holtet](#)

Document owner: [Arnfinn Granheim](#)

Verified: 30.12.2022 by [Jon Halvor Holtet](#)

Approved: 30.12.2022 by [Arnfinn Granheim](#)

Planned review by: 30.12.2025

Keywords: EI-sikkerhet

Based on the Norwegian document SDOK-515-12

1 Governing policy and legislation

These Instructions for the Safety Supervisor LV are subordinate to [policy sikkerhet](#) (Safety Policy). They are a supplement to, and superceded by [FSE 2006](#) (Safety regulations related to the maintenance and operation of electrical installations) and "[Forskrift om elektroforetak og kvalifikasjonskrav for arbeid knyttet til elektriske anlegg og elektrisk utstyr](#)" (Regulations concerning electrical enterprises and qualifications requirements for work related to electrical installations and equipment), both of which are pursuant to the "[Lov om tilsyn med elektriske anlegg og elektrisk utstyr](#)" (Act relating to the Inspection of Electrical Installations and Electrical Equipment).

2 Purpose and validity

The purpose of these Instructions is to ensure a high level of safety during work on or in the vicinity of Statnett electrical installations and during their operation, by requiring adequate planning of all activities and the implementation of necessary safety measures to avoid any threat to life, health, or property.

These Instructions apply to all low voltage installations where a Statnett Operations Manager HV has authority as Operations Manager LV.

3 Intended audience

Operative personnel in Statnett and internal and external employees who are certified Safety Supervisor LV on electrical installations where Statnett has operational responsibility.

4 Definitions

Operations Manager LV (low voltage): Person appointed by the owner/manager to carry out and be responsible for the ongoing management and maintenance of electrical installations.

Operations Manager HV (high voltage): Person appointed by the owner/manager to carry out and be responsible for the ongoing management and maintenance of electrical installations.

Low voltage: Voltages that normally do not exceed 1000 V a.c. or 1500 V d.c.

Safety Supervisor LV (low voltage): Person appointed to have responsibility for the electrical safety at the worksite (low voltage).

Instructed Personnel: Person who is adequately instructed to ensure he or she is in a position to understand risk and to avoid danger related to electricity. May be accompanied and supervised by a competent person if necessary.

5 Work on or in the vicinity of a low voltage installation

- 5.1 All work in low voltage installations must be planned in advance.
- 5.2 Work on low voltage installations may be conducted according to the procedures for work on **disconnected installations** or work on or in the vicinity of **energised installation components**. Refer to the procedures enclosed with these Instruction.
- 5.3 Necessary safety measures must be initiated. See attached procedures.
- 5.4 A **Safety Supervisor LV** must be appointed for every work task on or in the vicinity of an exposed low voltage electrical installation. This includes fuse replacement for which Instructed Personnel are required (service not safeguarded against direct contact) and voltage measuring on a voltage transformer. The appointment process must follow section 4.6 in [Electrical safety procedural works](#): Appointing Safety Supervisor HV for work on disconnected installations or in the vicinity of high voltage installations, and appointing Safety Supervisor LV for work on or in the vicinity of low voltage installations.
- 5.5 The Safety Supervisor LV must be able to communicate directly (without the use of an interpreter) with the person who has made the appointment or their substitute, and with the rest of the work team.
- 5.6 The Safety Supervisor LV must be present during all work.
- 5.7 **Applying particularly to work on the secondary side of transformer circuits**
- 5.7.1 When working with **electrical circuits in operation** (secondary side of current transformers), where **test plugs/test switches are not used**, there must always be at least two persons present, one of which must be the Safety Supervisor LV. For the second person, an **independent access permit** is required (ref. [Instructions for training/access/safety cards to Statnett's electrical installations](#)) on the installation and the person must have a relevant trade certificate or relevant approval for the task by the Directorate for Civil Protection. The name of the second person must be documented by the Safety Supervisor LV in the duty journal.
- 5.7.2 The Safety Supervisor LV is responsible for implementing necessary short circuiting on the secondary side of transformers and/or other safety measures, to prevent overvoltages caused by open secondary circuits. The second person must check that the correct current clamps are opened.
- 5.7.3 When working on **current transformer secondary circuits in operation**, where **test plug is used**, only one person is required. This person must be assigned as Safety Supervisor LV, ref. 5.4.
- 5.7.4 If there is any suspicion that the open current transformer secondary circuit or terminal blocks are not properly tightened, the Safety Supervisor LV must contact the affected Regional Control Centre for immediate disconnection of the transformer.
- 5.7.5 **Circuits on the secondary side of the transformer** may be considered as **not in operation**, and the two-persons present requirement does not apply, if the associated current transformer is blocked against conducting current on the primary (disconnected) side (cf. 5.7.6). For bays with a double switch system with double

current transformers the bay (both branches) must be blocked.

- 5.7.6 Blocking of primary current (disconnection) must be conducted in accordance with section 5.4 in [Electrical safety procedural works](#): Arbeid i sekundærkrets på strømtransformator med frakoblet primærside (Work in the secondary circuit on current transformers with the primary side disconnected, Norwegian document only).

5.8 Applying particularly to work in control circuit

- 5.8.1 When demolition, testing or troubleshooting in control circuits for disconnectors and earthing switches, the motor fuses for the affected breaker must be disconnected before disconnecting control circuits, isolating links in terminal blocks are split or conductors in control circuits are disconnected.

5.9 Notifying the Regional Control Centre of work in the substation automation system

- 5.9.1 Before work may start at the beginning of each day, the Safety Supervisor LV must contact the Regional Control Centre, informing them of the planned work on the substation automation system. This also applies to bays where another company has switching authority.
- 5.9.2 The Regional Control Centre must receive clear information about which part of the installation will be affected by the work, the name of the Safety Supervisor LV, the scope of the job and how long it will last.
- 5.9.3 The Safety Supervisor LV is not permitted to allow work to start before receiving permission from the Regional Control Centre. The Regional Control Centre may refuse to give permission for work to start.

5.10 Informing the Monitoring Centre if work could affect substation surveillance equipment or ICT equipment

- 5.10.1 Notification of all work involving an uninterruptible power supply (rectifier, inverter and battery system/UPS) must be given to the Monitoring Centre (71 68 90 20) before commencement.
- 5.10.2 The Safety Supervisor LV must assess whether the planned work on the substation automation system could affect the remote-control function (RTU, substation computer, computer networks, etc.), kWh meters or the substation surveillance equipment (access control, camera functions, key cabinets etc). If there is a risk of any such functions being affected, the Monitoring Centre must be informed before work may be started.
- 5.10.3 If work could result in a full or partial shutdown of the surveillance system, the Monitoring Centre must be informed before this happens. The Monitoring Centre must also be notified when such work has been completed and the surveillance system is functioning as normal.
- 5.10.4 If the Monitoring Centre (with support from ICT personnel) and the Safety Supervisor LV decide that communications systems (remote control, relay protection and system protection communication) could be affected by the work on uninterruptible power supply or the substation automation system, the Monitoring Centre must notify the applicable Regional Control Centre and ID Officer.

6 Abstinance from alcohol

The person appointed as Safety Supervisor LV must agree to refrain from consuming alcohol or other intoxicants during the 8 hours prior to starting work.

7 Confirmation of compliance

The responsibility for checking compliance with instructions lies with the document holder and approving body.

The position of Operations Manager LV includes authority to draw up and approve work procedures, guidelines and instructions in areas covered by electrical safety in accordance with [policy sikkerhet](#) (Safety Policy – Norwegian document only).

8 Enclosures and references

Enclosures:

- Procedure A: Procedure for work on de-energised installations
- Procedure B: Procedure for working on or in the vicinity of energised installations
- Procedure C: Procedure for working on or in the vicinity of energised installations in control panels/ cabinets/ field cabinets.

References:

- [Policy sikkerhet](#) (Safety Policy – Norwegian document only) (SDOK-856-6)
- [Instructions for the Safety Supervisor HV](#) (SDOK-515-55)
- [Instruction for training/access/safety cards to Statnett's electrical installations](#) (SDOK-515-60)
- [Instruks for vernebekledning](#) (Instructions for personal protective equipment - Norwegian document only) (SDOK-587-20)
- [Instruks for planlegging av arbeid i elektriske anlegg](#) (Instructions for planning of work in electrical installations – Norwegian document only) (SDOK-515-36)
- [Electrical safety procedural works](#) (SDOK-515-73)
- [Safety regulations related to the maintenance and operation of electrical installations](#) (www.dsb.no)
- [Forskrift om elektroforetak og kvalifikasjonskrav for arbeid knyttet til elektriske anlegg og elektrisk utstyr](#) (Regulations concerning electrical enterprises and qualifications requirements for work related to electrical installations and equipment – only in Norwegian) (www.lovdatab.no)
- [Lov om tilsyn med elektriske anlegg og elektrisk utstyr](#) (Act relating to the Inspection of Electrical Installations and Electrical Equipment – only in Norwegian) (www.lovdatab.no)

9 Version log

Valid as of	Revision classification (New/Updated/Vocabulary/None)	Description of important changes
01.01.2023	Updated	5.10 and 5.11 are united together because the Monitoring Centre is now monitoring both substation surveillance equipment and ICT equipment. Changed reference from Functional Policy Electrical Safety to Safety Policy. Changed reference from separately procedures to procedural works.

10 PROCEDURE A – WORKING ON DE-ENERGISED INSTALLATIONS

10.1 Necessary equipment

Personal protective equipment must include:

- Helmet – can be omitted when safety measures according to pt. 10.2 are in place, unless other factors make use of helmet necessary.
- Clothing according to [Instruks for vernebekledning](#)

Other equipment must include:

- Voltage testing equipment
- Signs and tagging equipment
- Short-circuiting equipment

10.2 Implementing safety measures

The following safety precautions must be in place before work is permitted to start (in the given order):

- 10.2.1 The section of the installation where work is planned must be de-energised.
- 10.2.2 The circuits energising the de-energised parts must be tagged and, if applicable, switches locked out, cf. pt. 10.2.4
- 10.2.3 Voltage tests must be conducted to verify that the circuit elements and parts are de-energised.
- 10.2.4 The workplace must be short circuited if the safety practices outlined in pt. 10.2.2 are not considered to provide adequate personal safety.
- 10.2.5 If a drill is used, all installation parts must be protected from boring chips.

10.3 Dismantling safety measures

The following procedures must be followed (in the given order) before the installation is allowed to be re-energised:

- 10.3.1 Notify all who have participated in the work that the installation part must now be considered energised.
- 10.3.2 Removal of all tools and barriers.
- 10.3.3 Removal of any short-circuiting equipment.
- 10.3.4 Removal of switch locking and (warning) tags.
- 10.3.5 Re-energising of the installation.

11 PROCEDURE B – WORKING ON OR IN THE VICINITY OF ENERGISED INSTALLATIONS

11.1 Necessary equipment

Personal protective equipment must include:

- Helmet
- Visor
- Insulated gloves
- Clothing according to [Instruks for vernebekledning](#)

Other equipment must include:

- Flexible insulating shrouding with clamps for shielding exposed live parts that could come into contact with body parts or tools (above, below and on all sides)
- Tools with insulated handles or totally insulated tools

11.2 Implementing safety measures

The following safety measures must be taken before work is permitted to start (in the given order):

11.2.1 Shielding of exposed live parts that could come into contact with body parts or tools (protect above, below and on all sides) using flexible insulating shrouding

11.2.2 If a drill is used, all installation parts must be protected from boring chips

11.2.3 All tools must be either totally insulated or with insulated handles

11.3 Before re-energisation

The following procedures must be followed (in the given order) before the installation is allowed to be re-energised:

11.3.1 Removal of all tools and insulating shrouding

11.3.2 Cleaning of shrouding after use

12 PROCEDURE C – WORK ON OR IN THE VICINITY OF ENERGISED INSTALLATIONS IN CONTROL SWITCHBOARDS/CABINETS/FIELD CABINETS

12.1 Working with control switchboards/cabinets/field cabinets

12.1.1 This procedure applies only to control switchboards/cabinets/field cabinets in circuits with 10 A fuses or less. Circuits in the same switchboard/cabinet that are fused higher than 10 A must be completely shielded by an insulating shroud. If shrouding is impossible, procedures A or B must be followed.

12.2 Necessary equipment

Personal protective equipment must include:

- Eye protection
- Clothing according to [Instruks for vernebekledning](#)
- Outdoors: Helmet

Other equipment must include:

- Flexible insulating shrouding with clamps for shielding exposed live parts that could come into contact with body parts or tools (protect above, below and on all sides)
- Tools with insulated handles or totally insulated tools

12.3 Implementing safety measures

12.3.1 Shielding of exposed live parts that could come into contact with body parts or tools (protect above, below and on all sides) using flexible insulating shrouding. If shrouding is not possible, insulated gloves must be used.

12.3.2 All tools must be either self insulated or double insulated.

12.3.3 Any connection or disconnection of auxiliary voltage must be via pillar terminal blocks in cabinets.

12.4 Before re-energisation

12.4.1 Removal of all tools and equipment.

12.4.2 Removal of all barriers and insulating shrouding.

12.4.3 Cleaning of insulating shrouding after use.

Instructions

Instructions for the Safety Supervisor LV

Revision log SDOK-515-56:

Revision	Approved	Approved by	Description
4.0	Show changes 30.12.2022	Arnfinn Granheim	See the version log
3.0	Show changes 29.12.2021	Arnfinn Granheim	See the version log
2.0	Show changes 29.12.2021	Arnfinn Granheim	See the version log
1.0	Show changes 08.12.2021	Arnfinn Granheim	Migrated from IFS#1406406